

Marek Kubala Jadwiga Królikowska

Faculty of Environmental Engineering, Cracow University of Technology

Dariusz Wawrentowicz

Faculty of Civil and Environmental Engineering, Bialystok University of Technology

EVALUATION OF THE PRACTICABILITY OF THE DECOMPOSITION AND EQUIVALENT SUBSTITUTION METHOD IN THE ANALYSIS OF RELIABILITY OF THE SEWAGE SYSTEM

Ocena praktycznego zastosowania metody dekompozycji i ekwiwalentnej zamiany w analizie niezawodności systemu kanalizacyjnego

Abstract

The work compares the accuracy of calculations of the reliability parameters of the sewerage network using the Decomposition and Equivalent Replacement (MDE) method, proposed by Yu. A. Yermolin and M.I. Alekseev [3], definitely simpler and less onerous in relation to the graph method. Comparing the results of calculations with both methods, applied to a simple network, one can come to the conclusion that the MDE calculations in simple cases give satisfactory accuracy. However, it would be necessary to check whether, as the complexity increases, this accuracy is still satisfactory.

Keywords: reliability, sewage network, graph, decomposition, equivalent substitution, failure

Streszczenie

W porównano dokładność obliczeń parametrów niezawodnościowych sieci kanalizacyjnej metodą dekompozycji i ekwiwalentnej zamiany (MDE), zaproponowaną przez Ju. A. Jermolina i M.I. Alieksjejewa [3], zdecydowanie prostszą i mniej uciążliwą w stosunku do metody grafów. Porównując wyniki obliczeń obiema metodami, zastosowane do prostej sieci, można dojść do wniosku, że obliczenia metodą MDE w prostych przypadkach dają zadowalającą dokładność. Należałoby jednak sprawdzić, czy w miarę wzrostu złożoności, dokładność ta jest nadal zadowalająca.

Słowa kluczowe: niezawodność, sieć kanalizacyjna, graf, dekompozycja, ekwiwalentna zamiana, awaryjność

1. Introduction

In addition to the largest and most common issues relating to the everyday usage of the gravitational sewage system – such as clogging of the sewer or its siltation and sedimentation – leakages are also a very significant problem. These may occur as a result of breakages, the overgrowth of roots, the displacement of pipes at the joints, or corrosion.

Whilst the effects of failures may be visible on the surface of the area where they occurred, e.g. collapses of the roadway or flooding of properties, they can also occur without any trace on the surface. This second type of failure can lead to technical disasters of the sewage system (especially gravitational), which are characterised by an impossibility of distinguish the idle time state. Moreover, the state of waiting for repair is usually discrete due to the fact that inspections of the system are held with a certain frequency.

One of the important parameters for assessing the reliability of a sewage system is the amount of sewage that is not disposed due to a failure. This value can be estimated by using the graph method [1, 2, 6, 8] which is basing on Markov's theory of processes. However, Yu. A. Yermolin and M.I. Alekseev [3] have proposed an alternative method of calculating the sewage system parameters which has been called the decomposition and equivalent substitution method (MDE).

The aim of the present research is to compare the two above-mentioned methods by calculating the amount of sewage that is not disposed due to a failure of sewage system with a simple spatial structure.

2. Graph method

The graph method is based on calculating the probabilities P_{Si} of all S_i states of a given network (or a branch of the network) and then multiplying them by the sum of effluences Q_{Si} of those segments from which in a given state the sewage is not disposed. The sum of these products gives the desired expected value of unreleased wastewater [1].

In order to calculate the probabilities of particular states, a matrix of the intensity of transitions Λ is constructed in which diagonal elements Λ_{ij} (i=j) represent the probability of leaving this state (1 minus the probability of staying in a given state), elements above the diagonal Λ_{ij} (i < j) represent the probability of entering the state S_i as a result of repairing the state S_j , elements below the diagonal Λ_{ij} (i > j) represent the probability of entering the state S_i due to failure of the state S_i .

The matrix is quasi stochastic and its columns satisfy the property:

$$\sum_{i} \Lambda_{ij} = 0 \tag{1}$$

The direct result of this property is the fact that diagonal elements satisfy the dependence:

$$\Lambda_{ii} = -\sum_{i \neq j} \Lambda_{ji} \tag{2}$$

In practical usage, one assumes asymptotic (stationary) values of probabilities $P_{S'}$ assuming that the process is ergodic. In this case, they can be calculated as a solution of set of equations which can be written as a matrix equation:

$$\Pi \Lambda = 0 \tag{3}$$

where Π represents the vector of limit probabilities.

Such a set is of course indeterminate; therefore, to eliminate uncertainty, one of the equations is replaced with the following condition:

$$\sum_{i} P_{Si} = 1 \tag{4}$$

which leads to substitution of the appropriate row of matrix Λ by a vector of ones and substitution of the appropriate position in vector $\mathbf{0}$ by the value 1.

Further proceedings are already a simple issue of the matrix account.

3. The decomposition and equivalent substitution method

The decomposition and equivalent substitution method (MDE) [3, 8], which treats the sewerage network as a tree-like graph [5], is based on subsequent replacement of Y-shaped structures which are composed of two external edges (leaves of the graph) connected in the parent node and an edge having end at this node by an equivalent edge. Examples of such structures are shown in Fig. 1.




Fig. 1. Sewage network graph with outlined Y-shaped structures that are to be substituted by equivalent edges

In the next step, after receiving the new network structure, it is necessary to repeat the procedure described above until the whole network (or the branch of interest) is replaced with one equivalent channel.

At the substitution stage, the equivalent effluence q_{ϵ} of the Y-shaped structure is calculated being a simple sum of effluences q_{ϵ} of all sewers constructing the substituted structure. The expected value Q_{ϵ} of unreleased wastewater is also calculated. As an auxiliary value, a dimensionless γ_{ϵ} coefficient is also calculated, which for a single sewer is understood as quotient of failure rate λ and renewal μ intensities [8]:

$$\gamma_i = \frac{\lambda_i}{\mu_i} \tag{5}$$

While calculating the parameters of the equivalent sewer, it is assumed that the probability of simultaneous failure of two or more sewers is significantly smaller than the probability of the failure of a single sewer; thus, in the graph structure of the states of the Y-shaped structure, such states are not considered (Fig. 2).




Fig. 2. Scheme of substituting the Y-shaped structure with one equivalent sewer (a) and the corresponding graphs of states of these structures (b)

Under these assumptions, the Y-shaped structure can have 4 states: 0 – all three sewers are operational; 1 – sewer k1 is inoperable; 2 – sewer k2 is inoperable; 3 – sewer k3 is inoperable. Transitions between these states occur with the appropriate failure $(\lambda_1, \lambda_2, \lambda_3)$ or renewal (μ_1, μ_2, μ_3) intensities. For such a structure of the graph of states, the probabilities of these states are expressed by the formulas [3]:

$$P_{S0} = \frac{1}{1 + \gamma_1 + \gamma_2 + \gamma_3}$$

$$P_{S1} = \frac{\gamma_1}{1 + \gamma_1 + \gamma_2 + \gamma_3}$$

$$P_{S2} = \frac{\gamma_2}{1 + \gamma_1 + \gamma_2 + \gamma_3}$$

$$P_{S3} = \frac{\gamma_3}{1 + \gamma_1 + \gamma_2 + \gamma_3}$$
(6)

By knowing the probabilities of states and effluences of individual sewers, one is able to calculate the expected value of unreleased wastewater Q_{ϵ} . The same can be done for the equivalent structure which has only two states: 0 – sewer is operational; $\epsilon 1$ – sewer is inoperable. By determining the streams of failure and renewal intensities for the equivalent sewer as $\lambda_{\epsilon 1}$ and $\mu_{\epsilon 1}$, respectively, and the corresponding dimensionless parameter as $\gamma_{\epsilon 1}$, the following probabilities of states are obtained:

$$P_{S0} = \frac{1}{1 + \gamma_{e1}}$$

$$P_{Se1} = \frac{\gamma_{e1}}{1 + \gamma_{e1}}$$
(7)

The expected value of unreleased wastewater Q is calculated in the same way as before. The adoption of the key assumption:

$$Q = Q_{e} \tag{8}$$

and the comparison of the relevant analytical formulas which facilitate the calculation of these quantities as functions γ_i and $q_{i'}$ enables calculating both $\gamma_{e1'}$, as well as Q_e and P_{Se1} . The quantity of P_{Se1} should be understood as the probability of failure of the entire substituted structure.

At this point, analytical formulas obtained in this way will be deliberately withheld because the authors of the method have applied unnecessarily strong assumptions that reduce the usage of the method. These overly strong assumptions are [3]: 1) only those sewers which are the leaves in the graph structure of the network have effluence q_i greater than 0; 2) the network is a binary tree, i.e., apart from the nodes which are the ends of the leaves, each node joins only two inflow sewers and one outflow sewer.

As has been demonstrated [5], assumption 1) is not mandatory and disregarding it only slightly complicates the formulas used to calculate the values γ_{el} , as well as Q_{ϵ} . One can also disregard assumption 2) by introducing dummy complementary sewers to the graph structure with effluence and parameter γ with a value of '0'. This also enables to analysis of those nodes that have more than two inflow sewers as well as those nodes with only one inflow sewer.

For such modified assumptions, appropriate analytical formulas to calculate the values γ_{el} , and Q are as follows [5]:

$$Q_{e} = \frac{(\gamma_{2} + \gamma_{1})q_{2} + (\gamma_{3} + \gamma_{1})q_{3} + \gamma_{1}q_{1}}{1 + \gamma_{1} + \gamma_{2} + \gamma_{3}}T$$
(9)

and

$$\gamma_{e1} = \frac{(\gamma_2 + \gamma_1)q_2 + (\gamma_3 + \gamma_1)q_3 + \gamma_1q_1}{(1 + \gamma_3)q_2 + (1 + \gamma_2)q_3 + (1 + \gamma_2 + \gamma_3)q_1}$$
(10)

where T is time, for which the expected value of unreleased wastewater is calculated. Considering that:

$$Q_e = P_{Se1} (q_1 + q_2 + q_3) T$$
 (11)

it is also easy to calculate the value of P_{Se1} .

For the purpose of further analysis, solutions should be introduced for a structure where there is only one outflow sewer; therefore, sewer k3 in Fig. 2a and state 3 in Fig. 2b are not present. For such a system, value γ_{e1} is a simple consequence of equation (10):

$$\gamma_{e1} = \frac{(\gamma_2 + \gamma_1)q_2 + \gamma_1 q_1}{q_2 + (1 + \gamma_2)q_1} \tag{12}$$

whereas Q results directly from equation (9):

$$Q_{e} = \frac{\left(\gamma_{2} + \gamma_{1}\right)q_{2} + \gamma_{1}q_{1}}{1 + \gamma_{1} + \gamma_{2}}T\tag{13}$$

by a simple substitution of q_3 and γ_3 with '0'.

Full procedures for obtaining analytical formulas for appropriate cases, including the case with more than two inflow sewers, have already been provided in the mentioned research [5].

4. The accuracy of the decomposition and equivalent substitution method

In spite of such relaxed assumptions of the method, it contains simplifications that can potentially affect the final result of calculating the expected value of unrecovered sewage. Above all, the assumption of negligible low probability of simultaneous damage of two or more channels in the wound structure is still valid. Also the very fact of gradual reduction through the decomposition of the network structure means that in the next steps we are considering, we do not take into account the states of the remaining part.

Despite mitigation the method's assumptions, it contains simplifications that can potentially affect the final result of calculating the expected value of unreleased wastewater. Firstly, the assumption that there is a negligibly low probability of simultaneous failure of two or more sewers in the reduced structure still remains. Additionally, the fact that there is an incremental reduction through decomposition of the network's structure means that in the steps considered next, the state of the remaining parts of the aforementioned structure is not taken into account.

In order to validate the accuracy of the method, an analysis was performed of a simple sewage system structure of a small town in southern Poland [4] which is reduced to three collectors. By keeping the sewage system markings consistently as a rooted tree-like graph (as in Fig. 1), the numbering is carried out inversely to the direction of sewage runoff (Fig. 3a). Therefore, the node w0 is the ending tank of the network, sewer k1 runs from node k1 to k2 runs from node k3 to k3 runs from node k3 to k4 runs from node k3 to k4 runs from node k4 run




Fig. 3. Diagram of the analysed network and subsequent stages of its reduction (a) and the corresponding graph of states (b)

For such a network structure, the considered states in the graphs method are as follows:

 S_0 – state where all sewers are operational

 S_1 – state where sewer k3 I is inoperable

 S_2 – state where sewer k2 is inoperable

 S_3 – state where sewer k1 is inoperable

 S_4 – state where sewers k3 and k2 are inoperable

 S_5 – state where sewers k3 and k1 are inoperable

 S_6 – state where sewers k2 and k1 are inoperable

S₇ – state where all sewers are inoperable

The matrix of intensity of transits for such a case is 8×8 and appears as follows:

$$\begin{split} \Lambda = & \begin{pmatrix} -\left(\lambda_{3} + \lambda_{2} + \lambda_{1}\right) & \mu_{3} & \mu_{2} & \mu_{1} & \dots \\ \lambda_{3} & -\left(\mu_{3} + \lambda_{2} + \lambda_{1}\right) & 0 & 0 \\ \lambda_{2} & 0 & -\left(\lambda_{3} + \mu_{2} + \lambda_{1}\right) & 0 \\ \lambda_{1} & 0 & 0 & -\left(\lambda_{3} + \lambda_{2} + \mu_{1}\right) \\ 0 & \lambda_{2} & \lambda_{3} & 0 \\ 0 & \lambda_{1} & 0 & \lambda_{3} \\ 0 & 0 & \lambda_{1} & 0 & \lambda_{3} \\ 0 & 0 & \lambda_{1} & \lambda_{2} \\ 0 & 0 & 0 & 0 & 0 \end{pmatrix} \\ \dots 0 & 0 & 0 & 0 \\ \dots 0 & 0 & 0 & 0 \\ \mu_{2} & \mu_{1} & 0 & 0 \\ \mu_{3} & 0 & \mu_{1} & 0 \\ 0 & \mu_{3} & \mu_{2} & 0 \\ -\left(\mu_{3} + \mu_{2} + \lambda_{1}\right) & 0 & 0 & \mu_{1} \\ 0 & -\left(\mu_{3} + \lambda_{2} + \mu_{1}\right) & 0 & \mu_{2} \\ 0 & 0 & -\left(\lambda_{3} + \mu_{2} + \mu_{1}\right) & \mu_{3} \\ \lambda_{1} & \lambda_{2} & \lambda_{3} & -\left(\mu_{3} + \mu_{2} + \mu_{1}\right) \end{pmatrix} \end{split}$$

```
Adoption of empirically determined the failure and renewal unit intensities [4]:  \lambda 0 = 0.4 \cdot 10^{-4} km^{-1}h^{-1} = 0.35 \ km^{-1}a^{-1}   \mu 0 = 0.1 \ h^{-1}  leads to the following sewer parameters (Table 1):
```

Table 1. Sewer parameters of the analysed sewage system necessary for calculations in the two presented methods $\lceil 4 \rceil$

Sewer	Lenght [km]	Effluence [Q _n]	Intensity of failure [h-1]	Intensity of renewal [h-1]	Parameter γ [-]	
k1	1.0	0.16	0.000040	0.1	0.0000040	
k2	0.8	0.21	0.000032	0.1	0.0000032	
k3	5.5	0.63	0.000220	0.1	0.0000220	

For such a set of parameters, the calculated probabilities of appropriate states as well as sum of effluences from those sewers from which, in a given state, the wastewater would not be released are as follows (Table 2):

Table 2. Values of probabilities of the state of the analysed sewage system, sum of effluences of not disposed sewage as well as products of these values

State	Probability of state P _{Si}	Sum of effluences $Q_{s_i}[Q_n]$	$P_{Si} \cdot Q_{Si} [Q_n]$
S _o	0.99708679925	0.00	0
S ₁	0.00219359096	0.63	1.381962·10 ⁻³
S ₂	0.00031906778	0.84	2.680169·10 ⁻⁴
S ₃	0.00039883472	1.00	3.988347·10 ⁻⁴
		Sum S ₀ to S ₃	0.001650569
S ₄	0.0000070195	0.84	5.896372·10 ⁻⁷
S ₅	0.00000087744	1.00	8.774364·10 ⁻⁷
S ₆	0.00000012763	1.00	1.276271·10 ⁻⁷
S ₇	0.0000000028	1.00	2.807796·10 ⁻¹⁰
		Sum S ₀ to S ₇	0.002050409

Finally, the value of sewage that is not disposed due to failures calculated by the graph method as a sum of values from Column 4 of Table 2 is equal to Q = 0.002050409 Q.

It is easy to observe that in the analysed example, MDE needs to use reduction only twice. If the parameters of the first reduction (sewers k3 and k2 to sewer ke2) are marked as γ_{e2} , Q_{e2} and q_{e2} and, simultaneously, the parameters of the second reduction (sewers ke2 and k1 to sewer ke1) are marked as γ_{e1} , Q_{e1} and q_{e1} , then the results of these two reductions are as follows (Table 3):

Table 3. Results of calculations of the appropriate parameters of the KDE method in the analysed sewage system

Equivalent sewer	γ_{ei}	$q_{ei}[Q_n]$	$Q_{ei}[Q_n]$
$e_2^{}$	0.0019689171	0.84	0.001650640
$e_{_1}$	0.0020532435	1.00	0.002049036

It should be observed that Q_{e1} corresponds to the sought expected value of unreleased wastewater and Q_{e2} corresponds to the sum of values from Column 4 of Table 2 for states 1, 2, and 3 which gives the result of 0.001650569.

It can be observed that in both cases, values Q_{r1} and Q_{r2} are almost identical to the values calculated when using graph method.

5. Conclusions

By comparing the results obtained by using both methods, one can conclude that MDE provides results that are sufficiently satisfactory for calculating the expected value of unreleased wastewater. It is obvious that the analysed case is very simple and one can deliberate whether possible deviations from the values obtained by more precise methods would become greater with increasing amount of elements in the network or with its structural complexity. Further analysis is therefore needed with special attention given to the influence of network complexity on the precision of calculations.

References

- [1] Bobrowski D., Modele i metody matematyczne teorii niezawodności, WNT, Warszawa 1985.
- [2] Galperin E.M, Steklov A.K., *Wybór wskaźników oceny sieci kanalizacyjnej*, Wodociągi i Inżynieria Sanitarna, Nr 12, 2000.
- [3] Yermolin Yu.A., Alekseev M.I., *Metoda dekompozycji i równoważności sieci kanalizacyjne*j, Wodociągi i Inżynieria Sanitarna, 11/2012, 51–57.
- [4] Królikowska J., Niezawodność funkcjonowania i bezpieczeństwa sieci kanalizacyjnej, Wydawnictwo PK, Kraków 2010.
- [5] Królikowska J., Kubala M., Analiza problemów praktycznego zastosowania metody dekompozycji i ekwiwalentowania, Czasopismo Inżynierii Lądowej, Środowiska i Architektury, 3/I/2015, 243–252.
- [6] Iwanejko R., Ocena dokładności miar niezawodnościowych systemów wodociągowych i kanalizacyjnych, Część I. Oceny wstępne, Czasopismo Techniczne, 2-Ś/2009, 13–25.
- [7] Tchorzewska-Cieslak B., Rak J., Markow reliability models for water supply system (WSS), Zeszyty Naukowe Politechniki Rzeszowskiej, Budownictwo i Inżynieria Środowiska, 22/2005, 717–728.
- [8] Wieczysty A., Niezawodność systemów wodociągowych i kanalizacyjnych, Wydawnictwo PK, Kraków 1990.

If you want to quote this article, its proper bibliographic entry is as follow: Kubala M., Królikowska J., Wawrentowicz D., Evaluation of the practicability of the decomposition and equivalent substitution method in the analysis of reliability of the sewage system, Technical Transactions, Vol. 5/2018, pp. 119–128.